



Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

LABORATORY RESULTS

Client: CHANNAHON EAST
Address: 24555 S. NAVAJO DR.
City, State, Zip: CHANNAHON, IL 60410
Temperature C:

Date Received : 06/30/22
Facility Number: 1970070
Funding Code: PW32

Client Sample ID: **LP3R002**
Matrix: Drinking Water
Sample Type:

Lab Sample ID: **22F1569-01**
Date/Time Collected: 06/29/22 5:40
Collected By:

Metals (Drinking Water) by EPA 200 Series Methods ICP/MS

Method: 200.8
Units: ug/L

Prepared: 07/20/22 10:20
Analyzed: 07/20/22 12:28

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	ND		50.0	1300

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact Tom Weiss, Laboratory Manager, at 217.782.9780.

Reported:
07/26/22 09:07
Page 1 of 6



Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

LABORATORY RESULTS

Client: **CHANNAHON EAST**
Address: 24555 S. NAVAJO DR.
City, State, Zip: CHANNAHON, IL 60410
Temperature C:

Date Received : 06/30/22
Facility Number: 1970070
Funding Code: PW32

Client Sample ID: **LA1A011**
Matrix: Drinking Water
Sample Type:

Lab Sample ID: **22F1569-02**
Date/Time Collected: 06/28/22 6:00
Collected By:

Metals (Drinking Water) by EPA 200 Series Methods ICP/MS

Method: 200.8
Units: ug/L

Prepared: 07/20/22 10:20
Analyzed: 07/20/22 12:30

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	733		50.0	1300

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact Tom Weiss, Laboratory Manager, at 217.782.9780.

Reported:
07/26/22 09:07
Page 2 of 6



Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

LABORATORY RESULTS

Client: **CHANNAHON EAST**
Address: 24555 S. NAVAJO DR.
City, State, Zip: CHANNAHON, IL 60410
Temperature C:

Date Received : 06/30/22
Facility Number: 1970070
Funding Code: PW32

Client Sample ID: **LP3R005**
Matrix: Drinking Water
Sample Type:

Lab Sample ID: **22F1569-03**
Date/Time Collected: 06/28/22 7:30
Collected By:

Metals (Drinking Water) by EPA 200 Series Methods ICP/MS

Method: 200.8
Units: ug/L

Prepared: 07/20/22 10:20
Analyzed: 07/20/22 12:33

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	274		50.0	1300

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact Tom Weiss, Laboratory Manager, at 217.782.9780.

Reported:
07/26/22 09:07
Page 3 of 6



Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

LABORATORY RESULTS

Client: **CHANNAHON EAST**
Address: 24555 S. NAVAJO DR.
City, State, Zip: CHANNAHON, IL 60410
Temperature C:

Date Received : 06/30/22
Facility Number: 1970070
Funding Code: PW32

Client Sample ID: **LP3R003**
Matrix: Drinking Water
Sample Type:

Lab Sample ID: **22F1569-04**
Date/Time Collected: 06/28/22 7:45
Collected By:

Metals (Drinking Water) by EPA 200 Series Methods ICP/MS

Method: 200.8
Units: ug/L

Prepared: 07/20/22 10:20
Analyzed: 07/20/22 12:36

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	563		50.0	1300

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact Tom Weiss, Laboratory Manager, at 217.782.9780.

Reported:
07/26/22 09:07
Page 4 of 6



Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

LABORATORY RESULTS

Client: CHANNAHON EAST
Address: 24555 S. NAVAJO DR.
City, State, Zip: CHANNAHON, IL 60410
Temperature C:

Date Received : 06/30/22
Facility Number: 1970070
Funding Code: PW32

Client Sample ID: **LP3R001**
Matrix: Drinking Water
Sample Type:

Lab Sample ID: **22F1569-05**
Date/Time Collected: 06/27/22 16:00
Collected By:

Metals (Drinking Water) by EPA 200 Series Methods ICP/MS

Method: 200.8
Units: ug/L

Prepared: 07/20/22 10:20
Analyzed: 07/20/22 12:39

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	586		50.0	1300

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact Tom Weiss, Laboratory Manager, at 217.782.9780.

Reported:
07/26/22 09:07
Page 5 of 6



Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

LABORATORY RESULTS

Client: CHANNAHON EAST
Address: 24555 S. NAVAJO DR.
City, State, Zip: CHANNAHON, IL 60410
Temperature C:

Date Received : 06/30/22
Facility Number: 1970070
Funding Code: PW32

Notes and Definitions

ND Analyte NOT DETECTED at or above the reporting limit

* Non-NELAP accredited

Report Authorized by:

Tom Weiss
Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact Tom Weiss, Laboratory Manager, at 217.782.9780.

Reported:
07/26/22 09:07
Page 6 of 6



Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

LABORATORY RESULTS

Client: CHANNAHON EAST
Address: 24555 S. NAVAJO DR.
City, State, Zip: CHANNAHON, IL 60410
Temperature C:

Date Received : 07/08/22
Facility Number: 1970070
Funding Code: PW32

Client Sample ID: LA3R009
Matrix: Drinking Water
Sample Type:

Lab Sample ID: 22G0202-01
Date/Time Collected: 07/07/22 7:15
Collected By:

Metals (Drinking Water) by EPA 200 Series Methods ICP/MS

Method: 200.8
Units: ug/L

Prepared: 07/20/22 13:40
Analyzed: 07/20/22 15:08

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	707		50.0	1300

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact Tom Weiss, Laboratory Manager, at 217.782.9780.

Reported:
07/26/22 09:06
Page 1 of 5



Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

LABORATORY RESULTS

Client: CHANNAHON EAST
Address: 24555 S. NAVAJO DR.
City, State, Zip: CHANNAHON, IL 60410
Temperature C:

Date Received : 07/08/22
Facility Number: 1970070
Funding Code: PW32

Client Sample ID: LA3R006
Matrix: Drinking Water
Sample Type:

Lab Sample ID: 22G0202-02
Date/Time Collected: 07/07/22 7:15
Collected By:

Metals (Drinking Water) by EPA 200 Series Methods ICP/MS

Method: 200.8
Units: ug/L

Prepared: 07/20/22 13:40
Analyzed: 07/20/22 15:13

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	1010		50.0	1300

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact Tom Weiss, Laboratory Manager, at 217.782.9780.

Reported:
07/26/22 09:06
Page 2 of 5



Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

LABORATORY RESULTS

Client: **CHANNAHON EAST**
Address: 24555 S. NAVAJO DR.
City, State, Zip: CHANNAHON, IL 60410
Temperature C:

Date Received : 07/08/22
Facility Number: 1970070
Funding Code: PW32

Client Sample ID: **LA3R007**
Matrix: Drinking Water
Sample Type:

Lab Sample ID: **22G0202-03**
Date/Time Collected: 07/06/22 7:45
Collected By:

Metals (Drinking Water) by EPA 200 Series Methods ICP/MS

Method: 200.8
Units: ug/L

Prepared: 07/20/22 13:40
Analyzed: 07/20/22 15:22

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	547		50.0	1300

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact Tom Weiss, Laboratory Manager, at 217.782.9780.

Reported:
07/26/22 09:06
Page 3 of 5



Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

LABORATORY RESULTS

Client: **CHANNAHON EAST**
Address: 24555 S. NAVAJO DR.
City, State, Zip: CHANNAHON, IL 60410
Temperature C:

Date Received : 07/08/22
Facility Number: 1970070
Funding Code: PW32

Client Sample ID: **LA3R008**
Matrix: Drinking Water
Sample Type:

Lab Sample ID: **22G0202-04**
Date/Time Collected: 07/06/22 5:20
Collected By:

Metals (Drinking Water) by EPA 200 Series Methods ICP/MS

Method: 200.8
Units: ug/L

Prepared: 07/20/22 13:40
Analyzed: 07/20/22 15:25

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	526		50.0	1300

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact Tom Weiss, Laboratory Manager, at 217.782.9780.

Reported:
07/26/22 09:06
Page 4 of 5



Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

LABORATORY RESULTS

Client: CHANNAHON EAST
Address: 24555 S. NAVAJO DR.
City, State, Zip: CHANNAHON, IL 60410
Temperature C:

Date Received : 07/08/22
Facility Number: 1970070
Funding Code: PW32

Notes and Definitions

- ND Analyte NOT DETECTED at or above the reporting limit
- * Non-NELAP accredited

Report Authorized by:

Tom Weiss
Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact Tom Weiss, Laboratory Manager, at 217.782.9780.

Reported:
07/26/22 09:06
Page 5 of 5



Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

LABORATORY RESULTS

Client: CHANNAHON EAST
Address: 24555 S. NAVAJO DR.
City, State, Zip: CHANNAHON, IL 60410
Temperature C:

Date Received : 07/13/22
Facility Number: 1970070
Funding Code: PW32

Client Sample ID: LA3R010
Matrix: Drinking Water
Sample Type:

Lab Sample ID: 22G0406-01
Date/Time Collected: 07/12/22 7:10
Collected By:

Metals (Drinking Water) by EPA 200 Series Methods ICP/MS

Method: 200.8
Units: ug/L

Prepared: 07/21/22 10:53
Analyzed: 07/21/22 13:31

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	702		50.0	1300

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact Tom Weiss, Laboratory Manager, at 217.782.9780.

Reported:
08/03/22 13:54
Page 1 of 2



Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

LABORATORY RESULTS

Client: CHANNAHON EAST
Address: 24555 S. NAVAJO DR.
City, State, Zip: CHANNAHON, IL 60410
Temperature C:

Date Received : 07/13/22
Facility Number: 1970070
Funding Code: PW32

Notes and Definitions

ND Analyte NOT DETECTED at or above the reporting limit

* Non-NELAP accredited

Report Authorized by:

Tom Weiss
Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact Tom Weiss, Laboratory Manager, at 217.782.9780.

Reported:
08/03/22 13:54
Page 2 of 2