



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: CHANNAHON

Facility Number: 1970200

Address: 24555 S. NAVAJO DRIVE

Date Received: 07/18/25

City, State, Zip: CHANNAHON, IL 60410

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8

Analyte Copper

Matrix: Drinking Water

Regulatory Level (ug/L): 1300

Units: ug/L

10 ug/L = 0.01 mg/L

<u>Lab ID</u>	<u>Sample Point</u>	<u>Sample Location</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Analysis Date</u>	<u>Sampled</u>
25G0786-01	LC5T010	24348 W Hummingbird	104		50.0	08/04/25 13:48	07/16/25 08:05
25G0786-02	LC5T021	24603 S Goldfinch	57.9		50.0	08/04/25 13:51	07/17/25 04:30



## Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

### LABORATORY RESULTS

Client: CHANNAHON

Facility Number: 1970200

Address: 24555 S. NAVAJO DRIVE

Date Received: 07/18/25

City, State, Zip: CHANNAHON, IL 60410

### Metals (Drinking Water) by EPA 200 Series Methods ICP/MS

Method: 200.8

Analyte Lead

Matrix: Drinking Water

Regulatory Level (ug/L): 15

Units: ug/L

10 ug/L = 0.01 mg/L

<u>Lab ID</u>	<u>Sample Point</u>	<u>Sample Location</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Analysis Date</u>	<u>Sampled</u>
25G0786-01	LC5T010	24348 W Hummingbird	ND		5.00	08/04/25 13:48	07/16/25 08:05
25G0786-02	LC5T021	24603 S Goldfinch	ND		5.00	08/04/25 13:51	07/17/25 04:30



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: CHANNAHON

Facility Number: 1970200

Address: 24555 S. NAVAJO DRIVE

Date Received: 07/18/25

City, State, Zip: CHANNAHON, IL 60410

**Notes and Definitions**

ND Analyte NOT DETECTED at or above the reporting limit

\* Non-NELAP accredited

Report Authorized by:

**Jewel Brant**  
Laboratory Manager



## Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

### LABORATORY RESULTS

Client: CHANNAHON

Facility Number: 1970200

Address: 24555 S. NAVAJO DRIVE

Date Received: 07/16/25

City, State, Zip: CHANNAHON, IL 60410

#### Metals (Drinking Water) by EPA 200 Series Methods ICP/MS

Method: 200.8

Analyte Copper

Matrix: Drinking Water

Regulatory Level (ug/L): 1300

Units: ug/L

10 ug/L = 0.01 mg/L

<u>Lab ID</u>	<u>Sample Point</u>	<u>Sample Location</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Analysis Date</u>	<u>Sampled</u>
25G0691-01	LC5T009	24314 W Hummingbird	79.3		50.0	07/31/25 22:35	07/15/25 06:15
25G0691-02	LC5T018	24224 W Hummingbird	75.5		50.0	07/31/25 22:38	07/15/25 05:30
25G0691-03	LC5T004	24513 S Valley Dr	87.5		50.0	07/31/25 22:41	07/15/25 05:00
25G0691-04	LC5T014	24628 S Teal Dr	69.9		50.0	07/31/25 22:44	07/15/25 07:05
25G0691-05	LC5T011	25145 W Meadowlark	101		50.0	07/31/25 22:47	07/15/25 05:15
25G0691-06	LC5T020	24538 S Valley Dr	105		50.0	07/31/25 22:50	07/15/25 05:40
25G0691-07	LC4T001	24305 W Hummingbird	112		50.0	08/04/25 09:31	07/15/25 06:45
25G0691-08	LC5T007	24628 S Valley Dr	103		50.0	08/04/25 09:34	07/15/25 06:00
25G0691-09	LC5T019	24625 S Valley Dr	129		50.0	08/04/25 09:50	07/15/25 06:15
25G0691-10	LC5T008	24506 S Valley Dr	97.7		50.0	08/04/25 09:47	07/15/25 06:30



## Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

### LABORATORY RESULTS

Client: CHANNAHON

Facility Number: 1970200

Address: 24555 S. NAVAJO DRIVE

Date Received: 07/16/25

City, State, Zip: CHANNAHON, IL 60410

#### Metals (Drinking Water) by EPA 200 Series Methods ICP/MS

Method: 200.8

Analyte Lead

Matrix: Drinking Water

Regulatory Level (ug/L): 15

Units: ug/L

10 ug/L = 0.01 mg/L

<u>Lab ID</u>	<u>Sample Point</u>	<u>Sample Location</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Analysis Date</u>	<u>Sampled</u>
25G0691-01	LC5T009	24314 W Hummingbird	ND		5.00	07/31/25 22:35	07/15/25 06:15
25G0691-02	LC5T018	24224 W Hummingbird	ND		5.00	07/31/25 22:38	07/15/25 05:30
25G0691-03	LC5T004	24513 S Valley Dr	ND		5.00	07/31/25 22:41	07/15/25 05:00
25G0691-04	LC5T014	24628 S Teal Dr	ND		5.00	07/31/25 22:44	07/15/25 07:05
25G0691-05	LC5T011	25145 W Meadowlark	ND		5.00	07/31/25 22:47	07/15/25 05:15
25G0691-06	LC5T020	24538 S Valley Dr	ND		5.00	07/31/25 22:50	07/15/25 05:40
25G0691-07	LC4T001	24305 W Hummingbird	ND		5.00	08/04/25 09:31	07/15/25 06:45
25G0691-08	LC5T007	24628 S Valley Dr	ND		5.00	08/04/25 09:34	07/15/25 06:00
25G0691-09	LC5T019	24625 S Valley Dr	5.58		5.00	08/04/25 09:50	07/15/25 06:15
25G0691-10	LC5T008	24506 S Valley Dr	ND		5.00	08/04/25 09:47	07/15/25 06:30



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: CHANNAHON

Facility Number: 1970200

Address: 24555 S. NAVAJO DRIVE

Date Received: 07/16/25

City, State, Zip: CHANNAHON, IL 60410

**Notes and Definitions**

ND Analyte NOT DETECTED at or above the reporting limit

\* Non-NELAP accredited

Report Authorized by:

**Jewel Brant**  
Laboratory Manager

Page 3 of 3

Reported: 08/27/25 10:41

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Federally regulated drinking water analytes are accredited by USEPA Region 5. All other analytes/methods are TNI accredited by Florida DOH #E37645, unless otherwise noted. If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: CHANNAHON

Facility Number: 1970200

Address: 24555 S. NAVAJO DRIVE

Date Received: 07/30/25

City, State, Zip: CHANNAHON, IL 60410

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8

Analyte Copper

Matrix: Drinking Water

Regulatory Level (ug/L): 1300

Units: ug/L

10 ug/L = 0.01 mg/L

<u>Lab ID</u>	<u>Sample Point</u>	<u>Sample Location</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Analysis Date</u>	<u>Sampled</u>
25G1280-01	LC5T003	26136 W Highland Dr	122		50.0	08/11/25 14:14	07/29/25 05:00
25G1280-02	LC5T005	25801 S Brookfield	95.9		50.0	08/11/25 14:17	07/29/25 06:40
25G1280-03	LC5T006	26839 S Overland Dr	57.6		50.0	08/11/25 14:22	07/29/25 06:25
25G1280-04	LC5T012	26420 W Winding Oak	171		50.0	08/11/25 14:25	07/29/25 05:45
25G1280-05	LC5T013	24359 S Dupage Dr	115		50.0	08/11/25 14:27	07/29/25 05:40
25G1280-06	LC5T015	24453 Great Oak Dr	107		50.0	08/11/25 14:35	07/29/25 04:00
25G1280-07	LC5T016	24308 W Quail Dr	87.1		50.0	08/11/25 14:38	07/29/25 07:35
25G1280-08	LC5T017	26136 Winding Oak Ct	91.0		50.0	08/11/25 14:40	07/29/25 05:23



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: CHANNAHON

Facility Number: 1970200

Address: 24555 S. NAVAJO DRIVE

Date Received: 07/30/25

City, State, Zip: CHANNAHON, IL 60410

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8

Analyte Lead

Matrix: Drinking Water

Regulatory Level (ug/L): 15

Units: ug/L

10 ug/L = 0.01 mg/L

<u>Lab ID</u>	<u>Sample Point</u>	<u>Sample Location</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Analysis Date</u>	<u>Sampled</u>
25G1280-01	LC5T003	26136 W Highland Dr	ND		5.00	08/11/25 14:14	07/29/25 05:00
25G1280-02	LC5T005	25801 S Brookfield	ND		5.00	08/11/25 14:17	07/29/25 06:40
25G1280-03	LC5T006	26839 S Overland Dr	ND		5.00	08/11/25 14:22	07/29/25 06:25
25G1280-04	LC5T012	26420 W Winding Oak	ND		5.00	08/11/25 14:25	07/29/25 05:45
25G1280-05	LC5T013	24359 S Dupage Dr	ND		5.00	08/11/25 14:27	07/29/25 05:40
25G1280-06	LC5T015	24453 Great Oak Dr	ND		5.00	08/11/25 14:35	07/29/25 04:00
25G1280-07	LC5T016	24308 W Quail Dr	ND		5.00	08/11/25 14:38	07/29/25 07:35
25G1280-08	LC5T017	26136 Winding Oak Ct	ND		5.00	08/11/25 14:40	07/29/25 06:23



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: CHANNAHON

Facility Number: 1970200

Address: 24555 S. NAVAJO DRIVE

Date Received: 07/30/25

City, State, Zip: CHANNAHON, IL 60410

**Notes and Definitions**

ND Analyte NOT DETECTED at or above the reporting limit

\* Non-NELAP accredited

Report Authorized by:

**Jewel Brant**  
**Laboratory Manager**

Page 3 of 3

Reported: 08/27/25 11:19

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Federally regulated drinking water analytes are accredited by USEPA Region 5. All other analytes/methods are TNI accredited by Florida DOH #E37645, unless otherwise noted. If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: CHANNAHON

Facility Number: 1970200

Address: 24555 S. NAVAJO DRIVE

Date Received: 08/27/25

City, State, Zip: CHANNAHON, IL 60410

School/Childcare location: 24805 W Roberts Ave

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8

Analyte: Lead

Matrix: Drinking Water

Regulatory Level (ug/L): 15

Units: ug/L

10 ug/L = 0.01 mg/L

<u>Lab ID</u>	<u>Sample Point</u>	<u>Sample Location</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Analysis Date</u>	<u>Sampled</u>
25H1172-01	SCH001A	DRINKING FOUNTAIN 1	ND		5.00	09/08/25 16:53	08/26/25 06:23
25H1172-02	SCH001B	DRINKING FOUNTAIN 2	ND		5.00	09/08/25 16:59	08/26/25 06:25
25H1172-03	SCH001C	KITCHEN	ND		5.00	09/08/25 17:02	08/26/25 06:19
25H1172-04	SCH001D	NURSES OFFICE	ND		5.00	09/08/25 17:06	08/26/25 06:21
25H1172-05	SCH001E	CLASSROOM	48.9		5.00	09/08/25 17:09	08/26/25 06:27



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **CHANNAHON**

Facility Number: **1970200**

Address: 24555 S. NAVAJO DRIVE

Date Received: **08/27/25**

City, State, Zip: **CHANNAHON, IL 60410**

School/Childcare location: **24805 W Roberts Ave**

**Notes and Definitions**

ND Analyte NOT DETECTED at or above the reporting limit

\* Non-NELAP accredited

Report Authorized by:

**Jewel Brant  
Laboratory Manager**

Page 2 of 2

Reported: 09/17/25 11:30

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Federally regulated drinking water analytes are accredited by USEPA Region 5. All other analytes/methods are TNI accredited by Florida DOH #E37645, unless otherwise noted. If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: CHANNAHON

Facility Number: 1970200

Address: 24555 S. NAVAJO DRIVE

Date Received: 08/27/25

City, State, Zip: CHANNAHON, IL 60410

School/Childcare location: 24735 W Eames St Unit 7

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8

Analyte: Lead

Matrix: Drinking Water

Regulatory Level (ug/L): 15

Units: ug/L

10 ug/L = 0.01 mg/L

<u>Lab ID</u>	<u>Sample Point</u>	<u>Sample Location</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Analysis Date</u>	<u>Sampled</u>
25H1171-01	DAYCARE001A	BATHROOM SINK	ND		5.00	09/08/25 16:47	08/26/25 06:09
25H1171-02	DAYCARE001B	KITCHEN	ND		5.00	09/08/25 16:50	08/26/25 06:11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: CHANNAHON

Facility Number: 1970200

Address: 24555 S. NAVAJO DRIVE

Date Received: 08/27/25

City, State, Zip: CHANNAHON, IL 60410

School/Childcare location: 24735 W Eames St Unit 7

**Notes and Definitions**

ND Analyte NOT DETECTED at or above the reporting limit

\* Non-NELAP accredited

Report Authorized by:

**Jewel Brant  
Laboratory Manager**

Page 2 of 2

Reported: 09/17/25 11:30

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Federally regulated drinking water analytes are accredited by USEPA Region 5. All other analytes/methods are TNI accredited by Florida DOH #E37645, unless otherwise noted. If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: CHANNAHON

Facility Number: 1970200

Address: 24555 S. NAVAJO DRIVE

Date Received: 08/29/25

City, State, Zip: CHANNAHON, IL 60410

School/Childcare location: 26136 W Leslie Dr

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8

Analyte: Lead

Matrix: Drinking Water

Regulatory Level (ug/L): 15

Units: ug/L

10 ug/L = 0.01 mg/L

<u>Lab ID</u>	<u>Sample Point</u>	<u>Sample Location</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Analysis Date</u>	<u>Sampled</u>
25H1285-01	DAYCARE002A	BATHROOM SINK	ND		5.00	09/10/25 14:37	08/28/25 05:45
25H1285-02	DAYCARE002B	KITCHEN	ND		5.00	09/10/25 14:40	08/28/25 05:47



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **CHANNAHON**

Facility Number: **1970200**

Address: 24555 S. NAVAJO DRIVE

Date Received: **08/29/25**

City, State, Zip: CHANNAHON, IL 60410

School/Childcare location: 26136 W Leslie Dr

**Notes and Definitions**

ND Analyte NOT DETECTED at or above the reporting limit

\* Non-NELAP accredited

Report Authorized by:

**Jewel Brant**  
**Laboratory Manager**

Page 2 of 2

Reported: 09/17/25 11:29

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Federally regulated drinking water analytes are accredited by USEPA Region 5. All other analytes/methods are TNI accredited by Florida DOH #E37645, unless otherwise noted. If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*